



Permit to Apply Certification Mark

Subject to the provisions of the Standards Act, 2008
(Act 8 of 2008), the relevant regulations made thereunder and the permit
conditions contained in the under mentioned schedules, this permit authorizes

**SOUTH OCEAN ELECTRIC WIRE COMPANY
(PTY) LTD
Co Reg. 1989/006650/07
ALBERTON**

to apply the certification mark



in respect of the mark specification

SANS 1574-2:2017

**TO: ELECTRIC FLEXIBLE CABLES WITH SOLID EXTRUDED DIELECTRIC
INSULATION**

**PART 2: PVC INSULATED FLEXIBLE CABLES FOR DOMESTIC, OFFICE
AND SIMILAR ENVIRONMENTS (CORDS)**

This permit, including schedule 1 to 3 which forms an integral part thereof:

- is issued without alteration;
- is identified by the applicable permit number;
- is subject to any condition or limitation contained therein;
- is valid subject to ongoing compliance with permit conditions;
- bears the embossed SABS Commercial seal. In the absence of the seal, the permit and the schedule shall be invalid; and
- the permit may be authenticated by referring to the register of "Certified Clients" on the SABS Commercial website (www.sabs.co.za)
- Scheme Type 5 permit applies to products that have been tested.

Permit Number

6840/16228

Effective Date

18 August 2026

Expiry Date

03 June 2029

Date of Original Registration

04 June 2014

Chief Executive Officer



SABS COMMERCIAL SOC Ltd.
1 Dr Lategan Ra, Groenkloof, Pretoria,
Republic of South Africa

A43 0007315

SCHEDULE TO PERMIT TO APPLY CERTIFICATION MARK

This permit is only applicable in respect of the permit holder, the factory, the mark specification, the commodity and the trade name or trade mark referred to in this schedule

1. Permit holder 1.1 Name 1.2 Name under which the business is conducted 1.3 Registration or the identity number	South Ocean Electric Wire Company (Pty) Ltd South Ocean Electric Wire Company (Pty) Ltd 1989/006650/07
2. Street address of factory at which the commodity is manufactured	12 Botha Street Alrode Ext 2 ALBERTON
3. Mark Specification with which the commodity is required to comply	SANS 1574-2 Electric flexible cables with solid extruded dielectric insulation Part 2: PVC insulated flexible cables for domestic, office and similar environments (cords)
4. Description of commodity to which the certification mark may be applied, and Brand name or Trade mark which may be used in conjunction with the certification mark	PVC-insulated flexible cords and cables for domestic use Single core flexible insulated wires and multi-core flexible cords of rated operating voltages up to and including 300V to earth and 500V between conductors and its untended for use with electric appliance in domestic office and similar applications. Conductor size 0.5-2.5mm ² P1 Normal duty, non-sheathed, 300/500V (H05V-F) P3 Light duty sheathed, flat 300/300V (H03VVH2-F) P5 Normal duty, sheathed, circular 300/500V (H05VV-F) P7 Light duty, sheathed, circular 300/300V (H03VV-F) P10 Normal duty, sheathed, flat 300/500V (H05VVH2-F)
5. Quality management system with which consistent compliance is required	The quality management system relating to the production of the commodities identified in section 3 and 4 of this schedule must consistently meet the requirements of the nominated product specification, the requirements for a product certification system 5 certification scheme as per ISO 17067 and requirements of the general and specific permit conditions as detailed in schedules 2 and 3 of the permit

SCHEDULE TO PERMIT TO APPLY CERTIFICATION MARK

This permit is only applicable in respect of the permit holder, the factory, the mark specification, the commodity and the trade name or trade mark referred to in this schedule

Schedule 1
Page 2 of 2**Record of amendments to permit**

Original date of issue : 2014-06-04

Amendments

2017-11-10	a) Permit reissued with a new triennial expiry date b) Post permit audit date 10 April 2017 c) Last permit expiry date 04 June 2017 d) Revision of specification from SANS 1574-2:2012 to SANS 1574-2:2016
2018-08-27	a) Permit re-issued with a new triennial expiry date b) Re-issue audit date 25 May 2018 c) Last permit expiry date 21 February 2018
2020-05-22	a) Permit reissued with a new triennial expiry date b) Re-issue audit date 11 May 2020 c) Last permit expiry date 04 June 2020 d) Revision of specification from SANS 1574-2:2016 to SANS 1574-2:2017
2023-07-18	a) Permit re-issued with triennial expiry date b) Post permit audit date 01 February 2023 c) Last permit expiry date 03 June 2023
2026-08-27	a) Permit re-issued with triennial expiry date b) Post permit audit date 10 February 2026 c) Last permit expiry date 03 June 2026