

SABS

Permit to Apply Certification Mark

Subject to the provisions of the Standards Act, 2008
(Act 8 of 2008), the relevant regulations made thereunder and the permit
conditions contained in the under mentioned schedules, this permit authorizes

SOUTH OCEAN ELECTRIC WIRE COMPANY (PTY) LTD

**Co Reg. 1989/006650/07
ALBERTON**

to apply the certification mark



in respect of the mark specification

SANS 1507-3:2020

**TO: ELECTRIC CABLES WITH EXTRUDED SOLID
DIELECTRIC INSULATION FOR FIXED INSTALLATIONS
(300/500 V TO 1 900/3 300 V)**

PART 3: PVC DISTRIBUTION CABLES

- This permit, including schedule 1 to 3 which forms an integral part thereof:
- is issued without alteration;
 - is identified by the applicable permit number;
 - is subject to any condition or limitation contained therein;
 - is valid subject to ongoing compliance with permit conditions;
 - bears the embossed SABS Commercial seal. In the absence of the seal, the permit and the schedule shall be invalid; and
 - the permit may be authenticated by referring to the register of "Certified Clients" on the SABS Commercial website (www.sabs.co.za)
 - Scheme Type 5 permit applies to products that have been tested.

Permit Number

6840/17711

Effective Date

16 May 2024

Expiry Date

22 May 2027

Date of Original Registration

23 May 2001

Chief Executive Officer



SABS COMMERCIAL SOC Ltd.
1 Dr Lategan Rd, Groenkloof, Pretoria,
Republic of South Africa

A4J 0008288

SCHEDULE TO PERMIT TO APPLY CERTIFICATION MARK

This permit is only applicable in respect of the permit holder, the factory, the mark specification, the commodity and the trade name or trade mark referred to in this schedule

Schedule 1

Page 1 of 2

1. Permit holder 1.1 Name 1.2 Name under which the business is conducted 1.3 Registration or the identity number	South Ocean Electric Wire Company (Pty) Ltd South Ocean Electric Wire Company (Pty) Ltd 1989/006650/07
2. Street address of factory at which the commodity is manufactured	25 Botha Street Alrode Ext 2 ALBERTON
3. Mark Specification with which the commodity is required to comply	SANS 1507-3 / SABS 1507-3 Electric cables with extruded solid dielectric insulation for fixed installations (300/500 V to 1 900/3 300 V) Part 3: PVC Distribution cables
4. Description of commodity to which the certification mark may be applied, and Brand name or Trade mark which may be used in conjunction with the certification mark	PVC distribution cables 1. 25-630mm ² PVC Distribution cables. Single Core Unarmoured 2. 120-630mm ² PVC Distribution cables. Single Core Armoured 3. 1-300mm ² PVC Distribution cables Multicore Unarmoured 4. 1-300mm ² PVC Distribution cables Multicore Armoured FLEX POWER SOUTH OCEAN ELECTRIC WIRE CO, SURFCAB
5. Quality management system with which consistent compliance is required	The quality management system relating to the production of the commodities identified in section 3 and 4 of this schedule must consistently meet the requirements of the nominated product specification, the requirements for a product certification system 5 certification scheme as per ISO 17067 and requirements of the general and specific permit conditions as detailed in schedules 2 and 3 of the permit

SCHEDULE TO PERMIT TO APPLY CERTIFICATION MARK

This permit is only applicable in respect of the permit holder, the factory, the mark specification, the commodity and the trade name or trade mark referred to in this schedule

Schedule 1

Page 2 of 2

Record of amendments to permit

Original date of issue : 2001-05-23

Amendments

2021-05-25

- a) Refer to permit no 10157 for amendments
- b) Permit separated from permit no 10157
- c) Permit extended by 6 months due to pandemic
- d) Post permit audit date 08 February 2021
- e) Last permit expiry date 27 May 2021

2021-09-27

- a) Permit reissued with a new triennial expiry date
- b) Post permit audit date 02 August 2021
- c) Last permit expiry date 27 November 2021
- d) Revision of specification from SANS 1507-3:2015 to SANS 1507-3:2020
- e) Alignment of expiry date
- f) The following commodity types removed 1.4 x (25 mm² to 120 mm²), PSC, PVC, PVC, SWA, PVC, FR 600/1 000 V cable
PVV/PVC/SWA/PVC (LHFR)(BLK/Blu) 600/1 000 V sizes from 1,5 mm² x 3 core up to 120 mm² x 4 core
Stranded copper conductors, PVC, PVC, SWA, ECC, PVC, FR 600/1 000 V cables from 4 mm² to 70 mm²
Reduced halogen emission and reduced flame propagation steel wire armour 600/1 000 V PVC cable
600/1 000 V PVC PVC SWA (FR) cables from 1,5 mm² to 16,0 mm²
600/1 000 V PVC PVC SWA PVC cables from 1,5 mm² to 16,0 mm²
Multicore cables armoured or unarmoured of voltages up to 1900/3300V with FR/LH Sheath for sizes up to 50 mm²
SOUTH OCEAN ELECTRIC WIRE CO, SURFAB
Single core flexible cable, PVC insulated, PVC nitrile sheathed 600/1 000 V

2024-05-16

- a) Permit reissued with a new triennial expiry date
- b) Post permit audit date 22 February 2024
- c) Last permit expiry date 22 May 2024